



Residents/Families/Visitors/Staff
DIA/State Lift Safety Codes

- No power strips (office use-electronics allowed if proper kind)
- No extension cords
- No heaters
- No curling irons (use allowed if supervised- not left in room)
- No hair dryers (use allowed if supervised- not left in room)
- No heating pads/electric blankets
- No vaporizers/humidifiers/dehumidifiers
- No more than 20% of surface coverage with flammable materials- art/quilts/giftwrap/door décor, etc.
- No cleaning agents
- No flammable aerosols (personal grooming products allowed)
- No plug-in air fresheners
- No blade-type fans
- No trip hazards- cords/tubing in open pathway
- No storage on floors- especially cardboard boxes
 - There must be 18-inch clearance from any sprinkler-head in all directions, including the closet
- Nothing hung on sprinklers/pipes or near heat- source/lighting (includes vents/above-bed light)
- No bar soap
- No throw/scatter/bathroom rugs
- No holes placed in doors- ask maintenance to assist
- Oxygen tanks must be secured in stand/base
- Oxygen sign must be posted on door, if two in the room
- Posted sign for staff/notify laundry if WRCC is not providing laundry services
- Have staff notify maintenance if want any pictures, clocks, etc. hung on walls
- No live Christmas trees/wreaths
- No candles/flames
- No halogen bulbs
- Christmas lights must be U.I. approved, low-heat type